

DECLARATION OF CONFORMITY



Liralighting Sp. z o.o, ul. E. Kwiatkowskiego 2, 82-300 Elbląg

hereby declare on our own responsibility, that the product(s):

KL 1 (Opal diffuser)

with parameters:

- 220-240V, 50-60Hz;
- LED; 2760lm 27W; 3000/4000K;
- class I, IP20.

Refers to the attachment

is in conformity with the following directives:

- DIRECTIVE **2014/35/EU** OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits
- DIRECTIVE **2014/30/EU** OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 26 February 2014 on the harmonisation of the laws of the Member States relating to electromagnetic compatibility
- DIRECTIVE **2011/65/EU** OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 8 June 2011 on the restriction of the use of certain hazardous substances in electrical and electronic equipment
- DIRECTIVE **2009/125/WE** OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 21 October 2009 establishing a framework for the setting of ecodesign requirements for energy-related products

and with the following harmonized standards:

- | | | |
|------------------------|------------------------|------------------------------------|
| - EN 60598-1:2015-04 | - EN 62471:2010 | - EN 61347-1:2015-09 |
| - EN 60598-2-2:2015-01 | - EN 61000-3-2:2019-14 | - EN 61347-2-13:2015-04/A1:2017-07 |
| - EN IEC 55015:2019-11 | - EN 61000-3-3:2013-10 | - EN 60598-1:2015-04/A1:2018-04 |
| - EN 61547:2009 | - EN IEC 63000:2019-01 | |


Liralighting Sp. z o.o.
Daniel Małecki
Director of R&D Dep.

Liralighting Sp. z o. o.
82-300 Elbląg, ul. E. Kwiatkowskiego 2
NIP 5783116708 REGON 361068640
tel. +48 55 236 11 85

Attachment

3020.10K

3021.10K

Liralighting Sp. z o.o.
Daniel Małecki
Director of R&D Dep.

● LIRALIGHTING
Liralighting Sp. z o. o.
82-300 Elbląg, ul. E. Kwiatkowskiego 2
NIP 5783116708 REGON 361068640
tel. +48 55 236 11 85